



Jim Doyle, Governor
Mary P. Burke, Secretary

December 7, 2006

KLENZOID, INC.
DIOX(R) WATER HYGIENE
JOE HANNIGAN
912 SPRING MILL AVE
PO BOX 389
CONSHOHOCKEN PA 19428

POWERSEAL PIPELINE PRODUCTS CORP.
CULLEN ALLRED
701 PLEASANT VIEW DR
WICHITA FALLS TX 76306

Re: Description: PIPE SADDLES-WATER
Manufacturer: POWERSEAL PIPELINE PRODUCTS CORP.
Product Name: TAPPED SADDLE CLAMPS
Model Number(s): 3131 AS
Product File No: 20060519

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (5)(d) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2011.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Size of the NPT tapped outlet must in accordance the below Table 1 entitled Minimum Outside Dimension of Pipe and Clamp Length for given NPT Tapped Outlet Size.

Table 1
Minimum Outside Dimension of Pipe and Clamp Length for given NPT Tapped Outlet Size

Outlet Size in inches	Minimum pipe OD in inches	Minimum Clamp Length in inches
3/4	2.38	6
1	2.38	6
1-1/4	2.88	8
1-1/2	3.50	8
2	3.50	8
3	6.63	12

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov